



Front View of Unit & Cylinder

Modulaire All-E + GC with UFH

- NOTES
- All plumbing fittings and outlets must be fitted in accordance with manufacturers instructions and have isolating flow rate and pressure reducing valves as required.
 - The installation must be in accordance with all relevant regulations All products specified on this drawing must be fitted in accordance with all of the manufacturers installation instruction manuals
 - All final pipework to Manifold to be 22 mm diameter for flow and common return and all UFH Circuit must be 16 mm.
 - Primary pipework must be installed to sizes stated in relevant boiler manufacturers data and takes precedence over size stated on the drawings
 - The first meter of pipework from the Heat pump to be copper, all pipework in the airing cupboard and all exposed pipework to be copper.
- KEY
- Flow and Return - F & R Hot
- Hot Water Supply - HWS
- Cold Water Supply - CWS
- Supply Mains Cold Water - MCW
- Pipework Rise To Above - T/A
- Pipework Drop To Below - T/B
- Pipework Drop From Above - F/A
- Pipework Rise From Below - F/B
- Space Heating Flow
- Common Return
- Domestic Hot Water Supply
- Domestic Cold Water Supply
- Drain
- 2 PORT VALVE (NON MOTORIZED)
- ISOLATION VALVE
- RELIEF VALVE
- PRESSURE REDUCING VALVE
- NON RETURN VALVE
- STAINER
- AUTOMATIC AIR VENT
- TEMPERATURE AND PRESSURE RELIEF VALVE
- PRESSURE GAUGE
- TEMPERATURE GAUGE
- 3 PORT VALVE
- This drawing to be read in conjunction with the design specification & schedules and any discrepancies must be reported to Joule UK prior to installation
- This drawing is protected under copyright laws

CLIENT	PROJECT	DRAWING TYPE	MODULAIR ALL E + GC - UFH DETAILS	
JOULE HEATING SOLUTIONS	JOULE HEATING SOLUTIONS	DRAWING TITLE	NOT TO SCALE	
ON BEHALF OF	HOUSE TYPE	DRAWING NUMBER	01/01/2024	SCALE 1:50 @ A3
JOULE HEATING SOLUTIONS	JOULE HEATING SOLUTIONS	DRAWING DATE	01/01/2024	REVISION 0

